

CLINTON TWP EXHIBIT B

Table 1
 Projected Annual Volume and Minimum Annual Volume

Fiscal Year Ending June 30	Projected Annual Volume (Mcf)	Minimum Annual Volume (Mcf)
2009	525,000	262,500
2010	525,000	262,500
2011	475,000	237,500
2012	475,000	237,500
2013	475,000	237,500
2014	475,000	237,500
2015	441,000	220,500
2016	441,000	220,500
2017	441,000	220,500
2018	441,000	220,500
2019	441,000	220,500
2020	430,000	215,000
2021	430,000	215,000
2022	430,000	215,000
2023	430,000	215,000
2024	430,000	215,000
2025	430,000	215,000
2026	430,000	215,000
2027	430,000	215,000
2028	<i>430,000</i>	<i>215,000</i>
2029	<i>430,000</i>	<i>215,000</i>
2030	<i>430,000</i>	<i>215,000</i>
2031	<i>430,000</i>	<i>215,000</i>
2032	<i>430,000</i>	<i>215,000</i>
2033	<i>430,000</i>	<i>215,000</i>
2034	<i>430,000</i>	<i>215,000</i>
2035	<i>430,000</i>	<i>215,000</i>
2036	<i>430,000</i>	<i>215,000</i>
2037	<i>430,000</i>	<i>215,000</i>
2038	<i>430,000</i>	<i>215,000</i>
2039	<i>430,000</i>	<i>215,000</i>

EXHIBIT B

Table 2
Pressure Range and Maximum Flow Rate

Calendar Year (Reopener Schedule in bold type)	Pressure Range (psi)		Pressure Range (psi)		Pressure Range (psi)		Pressure Range (psi)		Pressure Range (psi)		Maximum Flow Rate (mgd)	
	Meter CT-01		Meter CT-02		Meter CT-03		Meter CT-04		Meter CT-05		Max Day	Peak Hour
	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
2009	62	85	71	95	65	86	69	90	40	88	25.80	29.00
2010	62	85	71	95	65	86	69	90	40	88	25.80	29.00
2011	62	85	71	95	65	86	69	90	55	88	21.40	24.90
2012	62	85	71	95	65	86	69	90	55	88	21.40	24.90
2013	62	85	71	95	65	86	69	90	55	88	21.40	24.90
2014	62	85	71	95	65	86	69	90	60	88	21.4	26.6
2015	62	85	71	95	65	86	69	90	60	88	21.4	26.6
2016	62	85	71	95	65	86	69	90	60	88	21.4	26.6
2017	62	85	71	95	65	86	69	90	60	88	21.4	26.6
2018	62	85	71	95	65	86	69	90	60	88	21.4	26.6
2019	62	85	71	95	65	86	69	90	60	88	19.7	22.9
2020	62	85	71	95	65	86	69	90	60	88	19.7	22.9
2021	62	85	71	95	65	86	69	90	60	88	19.7	22.9
2022	62	85	71	95	65	86	69	90	60	88	19.7	22.9
2023	62	85	71	95	65	86	69	90	60	88	19.7	22.0
2024	62	85	71	95	65	86	69	90	60	88	19.7	22.0
2025	62	85	71	95	65	86	69	90	60	88	19.7	22.0
2026	62	85	71	95	65	86	69	90	60	88	19.7	22.0
2027	62	85	71	95	65	86	69	90	60	88	19.7	22.0
2028	62	85	71	95	65	86	69	90	60	88	19.7	22.0
2029	62	85	71	95	65	86	69	90	60	88	19.7	22.0
2030	62	85	71	95	65	86	69	90	60	88	19.7	22.0
2031	62	85	71	95	65	86	69	90	60	88	19.7	22.0
2032	62	85	71	95	65	86	69	90	60	88	19.7	22.0
2033	62	85	71	95	65	86	69	90	60	88	19.7	22.0
2034	62	85	71	95	65	86	69	90	60	88	19.7	22.0
2035	62	85	71	95	65	86	69	90	60	88	19.7	22.0
2036	62	85	71	95	65	86	69	90	60	88	19.7	22.0
2037	62	85	71	95	65	86	69	90	60	88	19.7	22.0
2038	62	85	71	95	65	86	69	90	60	88	19.7	22.0

EXHIBIT B

Table 3
Flow Split Assumptions

Meter	Assumed Flow Split (2023-2026)
CT-01	0 – 40 %
CT-02	0 – 20 %
CT-03	0 – 50 %
CT-04	0 – 40 %
CT-05	35 – 65 %

Table 4
Addresses for Notice

If to the Board: General Counsel Great Lakes Water Authority 735 Randolph, Suite 1901 Detroit, Michigan 48226	If to Customer: Township Clerk Charter Township of Clinton 40700 Romeo Plank Clinton Township, Michigan 48038 Cc: Township Supervisor Director of Public Services
--	--