

GROSSE POINTE WOODS EXHIBIT B

Table 1  
 Projected Annual Volume and Minimum Annual Volume

Fiscal Year Ending June 30	Projected Annual Volume (Mcf)	Minimum Annual Volume (Mcf)
2009	<b>105,000</b>	<b>52,500</b>
2010	<b>105,000</b>	<b>52,500</b>
2011	<b>85,000</b>	<b>42,500</b>
2012	<b>85,000</b>	<b>42,500</b>
2013	<b>85,000</b>	<b>42,500</b>
2014	<b>85,000</b>	<b>42,500</b>
2015	<b>92,000</b>	<b>46,000</b>
2016	<b>92,000</b>	<b>46,000</b>
2017	<b>92,000</b>	<b>46,000</b>
2018	<b>92,000</b>	<b>46,000</b>
2019	<b>92,000</b>	<b>46,000</b>
2020	<b>80,000</b>	<b>40,000</b>
2021	<b>80,000</b>	<b>40,000</b>
2022	<b>80,000</b>	<b>40,000</b>
2023	<b>80,000</b>	<b>40,000</b>
2024	<b>80,000</b>	<b>40,000</b>
2025	<b>80,000</b>	<b>40,000</b>
2026	<b>80,000</b>	<b>40,000</b>
2027	<b>80,000</b>	<b>40,000</b>
2028	<i>80,000</i>	<i>40,000</i>
2029	<i>80,000</i>	<i>40,000</i>
2030	<i>80,000</i>	<i>40,000</i>
2031	<i>80,000</i>	<i>40,000</i>
2032	<i>80,000</i>	<i>40,000</i>
2033	<i>80,000</i>	<i>40,000</i>
2034	<i>80,000</i>	<i>40,000</i>
2035	<i>80,000</i>	<i>40,000</i>
2036	<i>80,000</i>	<i>40,000</i>
2037	<i>80,000</i>	<i>40,000</i>
2038	<i>80,000</i>	<i>40,000</i>
2039	<i>80,000</i>	<i>40,000</i>

EXHIBIT B

Table 2  
Pressure Range and Maximum Flow Rate

Calendar Year (Reopener Schedule in bold type)	Pressure Range (psi)		Pressure Range (psi)		Pressure Range (psi)		Maximum Flow Rate (mgd)	
	Meter GW-01		Meter GW-02		Meter GW-03		Max Day	Peak Hour
	Min	Max	Min	Max	Min	Max		
2009	53	74	45	55	43	55	5.36	8.78
2010	53	74	45	55	43	55	5.36	7.07
2011	53	74	45	55	43	55	4.96	4.96
2012	53	74	45	55	43	55	4.96	4.96
2013	53	74	45	55	43	55	4.96	4.96
2014	53	74	45	55	43	55	4.96	4.96
2015	53	74	45	55	43	55	4.96	4.96
2016	53	74	45	55	43	55	4.96	4.96
2017	53	74	45	55	43	55	4.96	4.96
<b>2018</b>	53	74	45	55	43	55	4.96	4.96
2019	53	74	45	55	43	55	3.98	4.84
2020	53	74	45	55	43	55	3.98	4.84
2021	53	74	45	55	43	55	3.36	4.29
<b>2022</b>	53	74	45	55	43	55	3.36	4.29
2023	53	74	45	55	43	55	3.36	4.29
2024	53	74	45	55	43	55	3.36	4.29
2025	53	74	45	55	43	55	3.36	4.29
<b>2026</b>	53	74	45	55	43	55	3.36	4.29
2027	53	74	45	55	43	55	3.36	4.29
2028	53	74	45	55	43	55	3.36	4.29
2029	53	74	45	55	43	55	3.36	4.29
<b>2030</b>	53	74	45	55	43	55	3.36	4.29
2031	53	74	45	55	43	55	3.36	4.29
2032	53	74	45	55	43	55	3.36	4.29
2033	53	74	45	55	43	55	3.36	4.29
<b>2034</b>	53	74	45	55	43	55	3.36	4.29
2035	53	74	45	55	43	55	3.36	4.29
2036	53	74	45	55	43	55	3.36	4.29
2037	53	74	45	55	43	55	3.36	4.29
<b>2038</b>	53	74	45	55	43	55	3.36	4.29

EXHIBIT B

Table 3  
Flow Split Assumptions

<b>Meter</b>	<b>Assumed Flow Split (2023-2026)</b>
GW-01	90 – 100 %
GW-02	0 – 5 %
GW-03	0 – 10 %

Table 4  
Addresses for Notice

<b>If to the Board:</b>  General Counsel Great Lakes Water Authority 735 Randolph, Suite 1901 Detroit, Michigan 48226	<b>If to Customer:</b>  City Administrator City of Grosse Pointe Woods 20025 Mack Plaza Grosse Pointe Woods, Michigan 48236  Cc: Director of Public Services
--	---